



**DELHI POLLUTION CONTROL COMMITTEE**  
**WATER LABORATORY**  
4<sup>th</sup>FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06  
visit us at : <http://dpcc.delhigovt.nic.in>

**WATER QUALITY STATUS OF DRAIN**

REPORT NO: DPCC/W/D/2023/ 5660  
Date of Sampling: -03.05.2023

Date - 22/05/2023

S. No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	<b>Standards</b>	<b>5.5- 9.0</b>	<b>100</b>	<b>250</b>	<b>30</b>
1.	Najafgarh Drain	7.2	96	224	48
2.	Metcalf House Drain	7.1	44	80	20
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.3	92	240	40
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
8.	Civil Mill Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	SEN Nursing Home Drain	7.1	112	288	50
10.	Drain No. 14	NO FLOW	NO FLOW	NO FLOW	NO FLOW
11.	Power House Drain	7.2	108	272	48
12.	Indrapuri Drain	7.3	100	240	46
13.	Sonia Vihar Drain	7.4	120	320	54
14.	Kailash Nagar Drain	7.2	80	180	42
15.	Shastri Park Drain	7.1	50	144	34
16.	Barapulla Drain	7.3	108	272	56
17.	Maharani Bagh Drain	7.4	96	256	46
18.	Old Agra Canal Drain	7.3	88	224	43
19.	Jaitpur Drain	7.2	92	240	50
20.	Sarita Vihar Pool	7.1	76	200	38
21.	Tuglakabad Drain	7.3	108	288	52
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	NO FLOW	NO FLOW	NO FLOW	NO FLOW
24.	Shahdara Drain	7.2	108	304	54
25.	Sahibabad Drain	7.3	116	320	58
26.	Molarband Drain	7.1	72	256	42
27.	Abul Fazal Drain	7.4	104	336	50
28.	Supplementary Drain	7.2	84	208	40

*Nandita*

I/C Water Lab

**Dr. Nandita Moitra**  
Scientist 'D'