



DELHI POLLUTION CONTROL COMMITTEE
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhiqovt.nic.in>
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/20-21/313-336 / 2260

Date of Sampling- 06/07/2020

20/7/20

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.3	88	150	48
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	7.5	82	144	47
4.	Sweeper Colony Drain	7.2	88	148	48
5.	Magazine Road Drain	7.4	136	218	70
6.	ISBT Drain	7.1	78	154	48
7.	Tonga Stand Drain	7.1	108	184	60
8.	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	Civil Mill Drain	7.2	132	210	68
10.	Power House Drain	7.2	188	244	96
11.	Sen Nursing Home Drain	7.3	176	272	90
12.	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13.	Drain No. 14	7.6	122	144	64
14.	Barapulla Drain	7.6	24	110	36
15.	Maharani Bagh Drain	7.7	112	180	58
16.	Kalkaji Drain	7.8	106	170	56
17.	Sarita Vihar Drain (Mathura Road)	7.4	140	260	85
18.	Tehkhand Drain	7.9	52	78	24
19.	Tuglakabad Drain	8.0	114	182	60
20.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21.	Drain Near Sarita Vihar Bridge	7.8	32	80	24
22.	Shahdara Drain	7.6	120	202	66
23.	Sahibabad Drain	6.4	100	160	52
24.	Indrapuri Drain	7.9	280	430	142

N. Moitra

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

R. Sharma

SR. SCIENTIFIC ASSISTANT