



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
 4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
 visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/21-22/4603
 Date of Sampling: -08.02.2022

Dated: 04/03/2022

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	Discharge (m ³ /sec)
Standards		5.5- 9.0	100	250	30	
1.	Najafgarh Drain	7.34	156	320	85	33.09
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
5.	Magazine Road Drain	6.72	148	304	70	5
6.	ISBT Drain	7.12	140	224	64	0.50
7.	Tonga Stand Drain	6.94	68	160	42	0.69
8.	Civil Mill Drain	7.27	124	208	55	0.07
9.	Sen Nursing Home Drain	7.21	168	320	86	0.44
10.	Drain No. 14	7.54	24	74	20	0.07
11.	Power House Drain	7.46	164	272	70	1.38
12.	Indrapuri Drain	7.50	124	288	75	0.14
13.	Sonia Vihar Drain	7.27	212	384	95	1.24
14.	Kailash Nagar Drain	7.42	192	352	90	0.01
15.	Shastri Park Drain	7.14	132	240	66	0.20
16.	Barapulla Drain	7.34	116	266	63	2.05
17.	Maharani Bagh Drain	7.63	84	186	45	0.32
18.	Old Agra Canal Drain	7.78	120	208	54	0.20
19.	Jaitpur Drain	7.48	92	160	50	0.57
20.	Sarita Vihar Pool	7.52	80	144	48	2.48
21.	Tuglakabad Drain	7.67	20	67	11	0.72
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
24.	Shahdara Drain	7.48	136	320	83	5.63
25.	Sahibabad Drain	7.66	124	293	80	0.53
26.	Molarband Drain	7.42	96	213	66	0.36
27.	Abul Fazal Drain	7.58	108	266	62	0.24

G/62/ISBT/21/3/22

(Mr. Bohit)

[Signature]
 04/03/2022
 Manager (IT)

[Signature]

I/C Water Lab
 Dr. NANDITA MOITRA
 Scientist 'C'

[Signature]
 4/3/22