



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2024/ 1489
Date of Sampling: - 06/12/2024

Dated 23/12/24

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.29	104	210	78
2.	Metcalf House Drain				
3.	Khyber Pass Drain				
4.	Sweeper Colony Drain				
5.	Magazine Road Drain				
6.	ISBT Drain	7.15	112	250	90
7.	Tonga Stand Drain				
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.64	132	230	86
10.	Drain No. 14				
11.	Power House Drain	7.44	136	225	83
12.	Indrapuri Drain	7.29	116	195	77
13.	Sonia Vihar Drain	7.52	100	115	47
14.	Kailash Nagar Drain	7.64	140	225	87
15.	Shastri Park Drain	7.81	108	175	67
16.	Barapulla Drain	7.65	130	230	90
17.	Maharani Bagh Drain	7.73	122	190	80
18.	Old Agra Canal Drain				
19.	Jaitpur Drain	7.28	148	220	103
20.	Sarita Vihar Pool	7.42	120	240	110
21.	Tuglakabad Drain	7.31	108	180	73
22.	Drain Near LPG Bottling Plant				
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	7.86	92	190	83
24.	Shahdara Drain	7.79	164	310	120
25.	Sahibabad Drain	7.83	184	340	143
26.	Molarband Drain				
27.	Abul Fazal Drain	7.55	196	380	153

I/C WATER LAB

Dr. Nandita Moitra
Scientist 'D'

SSA/Analyst/SLA