



DELHI POLLUTION CONTROL COMMITTEE  
4<sup>th</sup>FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06  
visit us at : <http://dpcc.delhigovt.nic.in>  
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/19-20/169-192

11231

at 28-11-19

Date of Sampling- 4/11/19

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1	Najafgarh Drain	7.7	140	160	45
2	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3	Khyber Pass Drain	7.6	24	40	12
4	Sweeper Colony Drain	7.7	8	32	10
5	Magazine Road Drain	7.4	388	332	95
6	ISBT Drain	7.7	124	80	28
7	Tonga Stand Drain	7.9	40	120	38
8	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9	Civil Mill Drain	7.9	242	284	88
10	Power House Drain	8.2	64	80	24
11	Sen Nursing Home Drain	7.8	220	200	60
12	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13	Drain No. 14	7.9	14	32	8
14	Barapulla Drain	7.9	192	216	64
15	Maharani Bagh Drain	7.8	226	248	84
16	Kalkaji Drain	7.7	432	284	86
17	Sarita Vihar Drain (Mathura Road)	7.8	400	344	115
18	Tekhhand Drain	7.9	152	164	52
19	Tuglakabad Drain	8.0	268	248	70
20	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21	Drain Near Sarita Vihar Bridge	7.8	52	64	19
22	Shahdara Drain	7.7	460	388	115
23	Sahibabad Drain	7.8	748	516	160
24	Indrapuri Drain	8.0	60	308	100

SR. SCIENTIFIC ASSISTANT  
NANDITA MOITRA  
Scientist 'C'

SR. SCIENTIFIC ASSISTANT