



DELHI POLLUTION CONTROL COMMITTEE  
WATER LABORATORY  
4<sup>th</sup> FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06  
visit us at : <http://dpcc.delhigovt.nic.in>  
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/21-22/ 4001

Date of Sampling: - 08.06.2021

30/6/21

S. No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	Flow (m <sup>3</sup> /sec)
Standards		5.5- 9.0	100	250	30	
1.	Najafgarh Drain	7.12	132	256	52	31.5
2.	Metcalf House Drain	6.80	114	144	34	0.1
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	6.85	310	544	120	0.008
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	6.75	78	152	42	0.38
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	Civil Mill Drain	7.01	82	160	35	0.06
10.	Sen Nursing Home Drain	6.80	16	92	22	0.4
12.	Drain No. 14	6.72	12	60	6	0.07
13.	Power House Drain	7	104	218	54	0.67
14.	Indrapuri Drain	7.20	232	160	52	0.11
15.	Sonia Vihar Drain	6.40	104	148	44	2.40
16.	Kailash Nagar Drain	6.74	40	80	20	0.025
17.	Shastri Park Drain	6.02	70	192	44	0.12
18.	Barapulla Drain	7.06	18	176	32	1.09
19.	Maharani Bagh Drain	7.20	80	360	70	0.075
20.	Old Agra Canal Drain	7.32	52	152	34	1.56
22.	Jaitpur Drain	7.36	16	24	6	0.3
23.	Sarita Vihar Pool	7.26	10	24	5	1.55
24.	Tuglakabad Drain	7.23	22	72	14	0.35
25.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
26.	Drain Near Sarita Vihar Bridge	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
27.	Shahdara Drain	7.31	84	240	60	7.9
28.	Sahibabad Drain	7.18	148	213	70	0.4
29.	Molarband Drain	7.33	204	384	90	0.3
30.	Abul Fazal Drain	7.01	104	208	40	0.2

*Mitra*

I/C Water Lab

Dr. NANDITA MITRA  
Scientist