



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/22-23/5310

Date: 05/01/2023

Date of Sampling: -08.12.2022

S. No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.5	168	384	68
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	7.4	136	192	55
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.3	156	272	53
7.	Tonga Stand Drain	7.2	62	80	34
8.	Civil Mill Drain	7.1	120	288	52
9.	Sen Nursing Home Drain	7.4	164	336	62
10.	Drain No. 14	7.0	68	96	36
11.	Power House Drain	7.5	144	224	60
12.	Indrapuri Drain	7.0	160	304	63
13.	Sonia Vihar Drain	7.3	200	372	80
14.	Kailash Nagar Drain	7.5	152	248	58
15.	Shastri Park Drain	7.1	96	256	57
16.	Barapulla Drain	7.3	104	240	50
17.	Maharani Bagh Drain	7.4	100	266	54
18.	Old Agra Canal Drain	7.2	112	293	65
19.	Jaitpur Drain	7.3	128	208	48
20.	Sarita Vihar Pool	7.4	88	186	46
21.	Tuglakabad Drain	7.4	180	400	95
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	NO FLOW	NO FLOW	NO FLOW	NO FLOW
24.	Shahdara Drain	7.3	136	320	67
25.	Sahibabad Drain	7.5	140	346	70
26.	Molarband Drain	7.1	92	213	50
27.	Abul Fazal Drain	7.2	124	360	52
28.	Supplementary Drain	7.1	116	256	56

Nandita

I/C Water Lab

Dr. Nandita Moltra
Scientist 'D'