



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2024/1280

Dated: 01.10.2024

Date of Sampling: -04.09.2024

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.1	126	200	62
2.	Metcalf House Drain	7.4	31	48	22
3.	Khyber Pass Drain	NO FLOW			
4.	Sweeper Colony Drain	6.9	102	132	40
5.	Magazine Road Drain	NO FLOW			
6.	ISBT Drain	7.8	116	184	56
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.5	134	196	58
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	8.2	142	204	64
12.	Indrapuri Drain	7.3	160	284	85
13.	Sonia Vihar Drain	6.8	140	232	70
14.	Kailash Nagar Drain	NO FLOW			
15.	Shastri Park Drain	7.9	96	128	38
16.	Barapulla Drain	8.1	120	200	60
17.	Maharani Bagh Drain	7.6	158	248	72
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.2	152	300	90
20.	Sarita Vihar Pool	6.9	150	232	64
21.	Tuglakabad Drain	7.4	102	172	54
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	8.3	174	328	100
24.	Shahdara Drain	7.5	150	280	80
25.	Sahibabad Drain	8.2	110	148	44
26.	Molarband Drain	NO FLOW			
27.	Abul Fazal Drain	7.3	142	220	64

N. Moitra

I/C WATER LAB
Dr. Nandita Moitra
Scientist 'D'

[Signature]

SSA/Analyst/SLA