



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

Report No : DPCC/W/D/19-20/121-144 / 947

Date of Sampling 12-09-2019

Date - 01/10/19

S.No	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	General Standard	5.5- 9.0	100	250	30
1	Najafgarh Drain	8.9	188	80	26
2	Metcalf House Drain	7.9	38	40	11
3	Khyber Pass Drain	8.1	24	96	26
4	Sweeper Colony Drain	8.0	76	28	7.6
5	Magazine Road Drain	8.2	164	156	39
6	ISBT Drain	8.1	68	44	12
7	Tonga Stand Drain	8.1	384	144	37
8	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9	Civil Mill Drain	7.9	232	88	23.5
10	Power House Drain	7.9	164	156	42
11	Sen Nursing Home Drain	7.5	660	308	90
12	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13	Drain No. 14	7.7	44	96	27
14	Barapulla Drain	7.8	60	364	120
15	Maharani Bagh Drain	7.7	72	272	90
16	Kalkaji Drain	7.6	216	248	80
17	Sarita Vihar Drain (Mathura Road)	7.6	170	224	75
18	Tehkhand Drain	7.8	112	276	90
19	Tuglakabad Drain	7.7	400	360	120
20	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21	Drain Near Sarita Vihar Bridge	7.6	184	280	95
22	Shahdara Drain	7.6	232	256	85
23	Sahibabad Drain	7.8	556	424	156
24	Indrapuri Drain	7.7	172	408	145

Mishra
SR. SCIENTIST

[Signature]
SR. SCIENTIFIC ASSISTANT