



DELHI POLLUTION CONTROL COMMITTEE  
4<sup>th</sup>FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06

visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/20-21/ 385-408 / 2665

Date of Sampling- 05/10/2020

02/11/2020

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.5	58	124	30
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	7.6	20	48	14
4.	Sweeper Colony Drain	7.5	108	220	70
5.	Magazine Road Drain	7.6	70	156	42
6.	ISBT Drain	7.4	52	112	32
7.	Tonga Stand Drain	7.4	38	48	12
8.	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	Civil Mill Drain	7.4	76	184	48
10.	Power House Drain	7.3	112	292	70
11.	Sen Nursing Home Drain	7.3	96	168	34
12.	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13.	Drain No. 14	7.2	50	96	23
14.	Barapulla Drain	6.8	160	240	62
15.	Maharani Bagh Drain	7.0	324	400	160
16.	Kalkaji Drain	7.0	96	168	40
17.	Sarita Vihar Drain (Mathura Road)	7.1	210	320	125
18.	Tehkhand Drain	7.3	188	240	85
19.	Tuglakabad Drain	7.2	40	108	31
20.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21.	Drain Near Sarita Vihar Bridge	7.1	48	128	32
22.	Shahdara Drain	7.5	324	460	185
23.	Sahibabad Drain	7.5	264	320	175
24.	Indrapuri Drain	7.5	340	500	180

*Nandita*

SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

*R. H. Man*

SR. SCIENTIFIC ASSISTANT