



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
 4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
 visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2024/1425
 Date of Sampling: - 06/11/2024

Dated: 28.11.2024

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
Standards		5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.02	96	158	64
2.	Metcalf House Drain	NO FLOW			
3.	Khyber Pass Drain				
4.	Sweeper Colony Drain				
5.	Magazine Road Drain				
6.	ISBT Drain				
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.18	148	194	80
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	7.04	108	189	75
12.	Indrapuri Drain	7.56	108	179	70
13.	Sonia Vihar Drain	8.5	116	107	42
14.	Kailash Nagar Drain	7.37	112	158	62
15.	Shastri Park Drain	7.12	100	168	65
16.	Barapulla Drain	7.4	78	128	52
17.	Maharani Bagh Drain	7.48	84	148	60
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.12	104	168	65
20.	Sarita Vihar Pool	7.42	92	158	64
21.	Tuglakabad Drain	7.65	120	209	80
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	7.38	160	316	120
24.	Shahdara Drain	7.55	144	270	110
25.	Sahibabad Drain	7.13	144	260	105
26.	Molarband Drain	NO FLOW			
27.	Abul Fazal Drain	7.11	140	250	100

N. Mittal
I/C WATER LAB

B. Bhatia
SSA/Analyst/SLA

Dr. Nandita Mittal
 Scientist 'D'