

S. No	Site / Location No.	Name of STP	Operational Status	Capacity (in MGD)	Date of Sampling	Brief of Analysis Report
1	1	Kapashera	Operational	5	08.01.2019	Meeting the Prescribed Standards
2	2	Rohini	Operational	15	07.01.2019	<b>Not meeting the Prescribed Standards in respect of TSS(52 mg/l) and BOD(34 mg/l)</b>
3	3	Okhla Phase – I	Operational	30	09.01.2019	Meeting the Prescribed Standards
4	3	Okhla Phase – II	Operational	12	09.01.2019	Meeting the Prescribed Standards
5	3	Okhla Phase – III	Operational	37	09.01.2019	Non-operational due to under rehabilitation
6	3	Okhla Phase – IV	Operational	45	09.01.2019	Meeting the Prescribed Standards
7	3	Okhla Phase – V	Operational	16	09.01.2019	<b>Not meeting the Prescribed Standards in respect of TSS(56 mg/l) and BOD(36 mg/l)</b>
8	3	Okhla Phase – VI	Operational	30	09.01.2019	<b>Not meeting the Prescribed Standards in respect of TSS(26 mg/l) and BOD(20 mg/l)</b>
9	4	Akshardham /Common Wealth Games Village	Operational	1	18.01.2019	Meeting the Prescribed Standards
10	5	Yamuna Vihar Phase – I	Operational	10	18.01.2019	<b>Not meeting the Prescribed Standards in respect of TSS(72 mg/l) and BOD(42 mg/l)</b>
11	5	Yamuna Vihar Phase – II (Under Rehabilitation)	<b>Under Rehabilitation</b>	10	18.01.2019	Non-operational due to under rehabilitation
12	5	Yamuna Vihar Phase – III	Operational	25	18.01.2019	<b>Not meeting the Prescribed Standards in respect of TSS(36 mg/l) and BOD(26 mg/l)</b>
13	6	Mehrauli	Operational	5	17.01.2019	<b>Not meeting the Prescribed Standards in respect of TSS(48 mg/l) and BOD(32 mg/l)</b>
14	7	Vasant Kunj Phase – I	Operational	2	21.01.2019	Meeting the Prescribed Standards
15	7	Vasant Kunj Phase – II	Operational	3	21.01.2019	Meeting the Prescribed Standards
16	8	Rithala Phase – I	Operational	40	07.01.2019	<b>Not meeting the Prescribed Standards in respect of BOD(38 mg/l) and TSS (60 mg/l)</b>
17	8	Rithala Phase – II	Operational	40	07.01.2019	<b>Not meeting the Prescribed Standards in respect of BOD(36 mg/l) and TSS (56 mg/l)</b>

18	9	Nilothi Phase – I	Operational	40	15.01.2019	Not meeting the Prescribed Standards in respect of TSS(178 mg/l), BOD(85 mg/l), Oil & Grease(14.4 mg/l), COD (260 mg/l)and Dissolved Phosphates (6.8 mg/l)
19	9	Nilothi Phase – II	Operational	20	15.01.2019	Meeting the Prescribed Standards
20	10	Keshopur New ( Phase I) (Rehabilitated)	Operational	12	15.01.2019	Not meeting the Prescribed Standards in respect of BOD(44 mg/l) and TSS (64 mg/l)
21	10	Keshopur Phase–II(Rehabilitated)	Operational	20	15.01.2019	Not meeting the Prescribed Standards in respect of BOD(48mg/l), TSS (78 mg/l) and phosphates (5.2 mg/l)
22	10	Keshopur Phase – III (Rehabilitated)	Operational	40	15.01.2019	Not meeting the Prescribed Standards in respect of BOD(60 mg/l) and TSS (84 mg/l)
23	11	Najafgarh	Operational	5	10.01.2019	Not meeting the Prescribed Standards in respect of TSS(56 mg/l) and BOD(34 mg/l)
24	12	Pappankala Phase – I	Operational	20	10.01.2019	Not meeting the Prescribed Standards in respect of TSS(64 mg/l) and BOD(38 mg/l)
25	12	Pappankala Phase – II	Operational	20	10.01.2019	Meeting the Prescribed Standards
26	13	Dr. Sen Nursing Home Nalla	Operational	2.2	11.01.2019	Meeting the Prescribed Standards
27	14	Kondli Phase–I (Under Rehabilitation)	<b>Under Rehabilitation</b>	10	16.01.2019	Non-operational due to under rehabilitation
28	14	Kondli Phase – II	Operational	25	16.01.2019	Not meeting the Prescribed Standards in respect of TSS(68 mg/l) and BOD(48 mg/l)
29	14	Kondli Phase – III (Under Rehabilitation)	<b>Under Rehabilitation</b>	10	16.01.2019	Non-operational due to under rehabilitation
30	14	Kondli New ( Phase IV)	Operational	45	16.01.2019	Meeting the Prescribed Standards
31	15	Delhi Gate Nalla Phase – I	Operational	2.2	11.01.2019	Not meeting the Prescribed Standards in respect of TSS(16 mg/l)
32	15	Delhi Gate Nalla Phase – II	Operational	15	11.01.2019	Meeting the Prescribed Standards
33	16	Chilla	Operational	9	16.01.2019	Not meeting the Prescribed Standards in respect of TSS(24 mg/l) and BOD(26 mg/l)

34	17	Coronation Pillar (Old) [Closed for Rehabilitation]	<b>Under Rehabilitation</b>	10	-	
35	17	Coronation Pillar Phase – I & II	Operational	10	03.01.2019	Not meeting the Prescribed Standards in respect of TSS(56 mg/l) and BOD(36 mg/l)
36	17	Coronation Pillar Phase – III	Operational	10	03.01.2019	Not meeting the Prescribed Standards in respect of TSS(68 mg/l) and BOD(42 mg/l)
37	18	Ghitorni [Non Functional ]	<b>Non Functional</b>	5	-	
38	19	Molarband (Mini STP )	Operational	0.66	03.01.2019	Not meeting the Prescribed Standards in respect of BOD(38 mg/l) and TSS (54 mg/l)
39	20	Narela	Operational	10	08.01.2019	Not meeting the Prescribed Standards in respect of TSS(64 mg/l) and BOD(42 mg/l)
40	21	Bakkarwala (Mini STP) (Closed)	<b>Closed</b>	0.66	-	
41	22	Timarpur Oxidation Pond (Nehru Vihar)	<b>Closed</b>	6	-	
<p style="text-align: center;"><b>Installed Treatment Capacity --- 2759 MLD ( 607 MGD) [Excluding under Rehabilitation/ Closed ones ]</b>  <b>Monitoring of STPs is being done by DPCC on Monthly basis.</b>  <b>Out of 41 STPs of DJB, 33 STPs are having Online Monitoring System (OLMS) &amp; 34 STPs are operational.</b></p>						